



**BUREAU
VERITAS**

Świadectwo zgodności

Zgłaszający:

Kostal Industrie Elektrik GmbH
Lange Eck 11
58099 Hagen
Niemcy

Produkt:

Sieciowy falownik fotowoltaiczny (PV)

Model:

PLENTICORE 3.0	PIKO IQ 3.0
PLENTICORE 4.2	PIKO IQ 4.2
PLENTICORE 5.5	PIKO IQ 5.5
PLENTICORE 7.0	PIKO IQ 7.0
PLENTICORE 8.5	PIKO IQ 8.5
PLENTICORE 10.0	PIKO IQ 10.0

Zastosowanie zgodnie z przepisami:

Automatyczne urządzenie wyłączające, monitorujące sieć trójfazową w systemach fotowoltaicznych z obwodem równoległym trójfazowym poprzez przetwornicę w publicznej sieci zasilania. Automatyczne urządzenie wyłączające stanowi część wyżej wymienionej przetwornicy.

Zastosowane przepisy i normy:

EN 50549-1:2019, PN-EN 50549-1:2019

Wymagania dla instalacji generacyjnych przeznaczonych do równoległego przyłączania do publicznych sieci dystrybucyjnych -- Część 1: Przyłączanie do sieci dystrybucyjnej nN -- Instalacje generacyjne aż do typu B i wyłącznie z nim

EN 50438:2013, PN-EN 50438:2014

Wymagania dla instalacji mikrogeneracyjnych przeznaczonych do równoległego przyłączania do publicznych sieci dystrybucyjnych niskiego napięcia

DIN V VDE V 0126-1-1:2006 (4.1 Bezpieczeństwo Funkcjonalne)

Automatyczne urządzenie odłączające między generatorem a publiczną siecią niskiego napięcia

W momencie wydania niniejszego certyfikatu pojęcie zabezpieczenia interfejsu wyżej wymienionego, reprezentatywnego produktu spełnia wymagania bezpieczeństwa obowiązujące dla określonego zastosowania zgodnie z przepisami.

Numer raportu: 19TH0374-EN50549-1_0

Program certyfikacji: NSOP-0032-DEU-ZE-V01

Numer świadectwa: U19-0637

Data wydania:

2019-12-06

Institut certyfikacji



Holger Schaffer



**Deutsche
Akkreditierungsstelle**
D-ZE-12024-01-00

Institut certyfikacji Bureau Veritas Consumer Products Services Germany GmbH akredytowane zgodnie z normą DIN EN ISO/IEC 17065

Uma representação parcial do certificado requer a aprovação por escrito do Bureau Veritas Consumer Products Services

Appendix

Extract from test report according to EN 50549-1

Nr. 19TH0374-EN50549-1_0

Type Approval and declaration of compliance with the requirements of EN 50549-1.

Manufacturer / applicant:	Kostal Industrie Elektrik GmbH Lange Eck 11 58099 Hagen Germany			
Micro-generator Type	Grid-tied photovoltaic inverter			
	PLENTICORE 3.0	PLENTICORE 4.2	PLENTICORE 5.5	PLENTICORE 7.0
MPP DC voltage range [V]	180 - 720	180 - 720	225 - 720	290 - 720
Input DC voltage range [V]	180 - 1000	180 - 1000	225 - 1000	290 - 1000
Input DC current [A]	2x 13,0			3x 13,0
Output AC voltage [V]	3N~, 400V, 50Hz			
Output AC current [A]	4,33	6,74	8,82	11,23
Output power [VA]	3000	4200	5500	7000
	PLENTICORE 8.5	PLENTICORE 10.0		
MPP DC voltage range [V]	345 - 720	405 - 720		
Input DC voltage range [V]	345 - 1000	405 - 1000		
Input DC current [A]	3x 13,0			
Output AC voltage [V]	3N~, 400V, 50Hz			
Output AC current [A]				
Output power [VA]				
	PIKO IQ 3.0	PIKO IQ 4.2,	PIKO IQ 5.5	PIKO IQ 7.0
MPP DC voltage range [V]	180 - 720	180 - 720	225 - 720	290 - 720
Input DC voltage range [V]	180 - 1000	180 - 1000	225 - 1000	290 - 1000
Input DC current [A]	2x 13,0			3x 13,0
Output AC voltage [V]	3N~, 400V, 50Hz			
Output AC current [A]	4,33	6,74	8,82	11,23
Output power [VA]	3000	4200	5500	7000
	PIKO IQ 8.5	PIKO IQ 10.0		
MPP DC voltage range [V]	345 - 720	405 - 720		
Input DC voltage range [V]	345 - 1000	405 - 1000		
Input DC current [A]	3x 13,0			
Output AC voltage [V]	3N~, 400V, 50Hz			
Output AC current [A]	13,63	16,04		
Output power [VA]	8500	10000		
Firmware version	FW = 01.40 / PAR = 03.19			
Measurement period:	2019-08-02 to 2019-11-07			

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Appendix

Extract from test report according to EN 50549-1

Nr. 19TH0374-EN50549-1_0

Setting of the interface protection EN 50438 default:

Parameter	Max. disconnection time	Min. operate time	Trip value
Over voltage (stage 1) ^a	3s	-	230V +10% (253V)
Over voltage (stage 2)	0,2s	0,1s	230V +15% (264,5V)
Under voltage	1,5 s	1,2 s	230V -15% (195,5V)
Over frequency	0,5 s	0,3 s	50Hz +4% (52 Hz)
Under frequency	0,5 s	0,3 s	50Hz -5% (47,5 Hz)
Reconnection settings for voltage	0,85Vn (195,5V) ≤ V ≤ 1,10Vn (253V)		
Reconnection settings for frequency	49,5 Hz ≤ f ≤ 50,1 Hz		
Reconnection time	≥ 60 s		
Active power gradient after reconnection	10% P _{E_{max}} / per minute		
Permanent DC-injection	0,5% of rated inverter output current or 20mA		
Loss of mains according EN 62116 (LoM)	2,0 s		

Note:

^a Over voltage – stage1: 10 min-mean-value corresponding to EN 50160.

Default interface setting according to EN 50438:2013, PN-EN 50438:2013 are used.

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019. Any modification that affects the tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50549-1:2019.